

**NFPA 1901 or 1906
Waterous Model Aquis 1.5
Foam System Certification**

| Certified Manufacturer Type Test | | | | | | | | |
|--|--------|------|------------|------|----------------|-----|---------------|------|
| Waterous Plumbing Connection Ordered | Foam % | | Water Flow | | Water Pressure | | Foam Capacity | |
| | Range | % | Range | GPM | Range | PSI | Range | GPM |
| Tee or Manifold with 1-1/2 in. Thread or 2 in. Victaulic | Min | 0.01 | Min | 10 | Min | 0 | Min | 0.01 |
| | | | Max | 10 | Max | 400 | Max | 0.01 |
| | Mid | 0.50 | Mid | 150 | Mid | 150 | Mid | 0.80 |
| | Max | 1.00 | Min | 325 | Min | 0 | Min | 1.70 |
| Max | | | 325 | Max | 400 | Max | 1.30 | |
| Tee or Manifold with 2 in. Thread or 2-1/2 in. Victaulic | Min | 0.01 | Min | 20 | Min | 0 | Min | 0.02 |
| | | | Max | 20 | Max | 400 | Max | 0.02 |
| | Mid | 0.50 | Mid | 375 | Mid | 150 | Mid | 1.50 |
| | Max | 1.00 | Min | 750 | Min | 0 | Min | 1.70 |
| Max | | | 750 | Max | 400 | Max | 1.30 | |
| Tee or Manifold with 2-1/2 in. Thread or 3 in. Victaulic | Min | 0.01 | Min | 30 | Min | 0 | Min | 0.03 |
| | | | Max | 30 | Max | 400 | Max | 0.03 |
| | Mid | 0.50 | Mid | 300 | Mid | 150 | Mid | 1.50 |
| | Max | 1.00 | Min | 1200 | Min | 0 | Min | 1.70 |
| Max | | | 1200 | Max | 400 | Max | 1.30 | |

| OEM Certification Test | | | | | |
|------------------------|-------------|-----------------------|------------|--------------------|----------|
| Flowmeter | | Foam Pump Test Points | | | |
| Range | Test Points | Simulated Water Flow | Set Foam % | Water Pressure PSI | Foam GPM |
| Min | | | | | |
| Mid | | | | | |
| Max | | | | | |
| | | | | | |
| | | | | | |
| Min | | | | | |
| Mid | | | | | |
| Max | | | | | |
| | | | | | |
| | | | | | |
| Min | | | | | |
| Mid | | | | | |
| Max | | | | | |
| | | | | | |
| | | | | | |

Installer Certification:

Installed, Calibrated and Tested to Waterous Installation Recommendations and Purchaser's Performance Specifications.

Tester: _____

Date: _____